

Certificate of Conformity



Device: IN-LINE STABLE DETONATION FLAME ARRESTER
WITH PIPE AWAY BREATHER VALVE

Type: PROTEGO® DR/ES-V-DN-IIA-P(p_o)

flange connection DN mm	maximum operating pressure p _o bar (abs)
25	4,0
32	4,0
40	4,0
50	4,0
65	2,9
80	2,9
100	2,0
125	2,0
150	2,0

Protective System: GII 94/9/EG
Explosion Group: IIA

Marking: II G IIA

Max. operating temperature:
+ 60°C

Manufacturer: Braunschweiger Flammenfilter GmbH
Industriestraße 11, 38110 Braunschweig

The above mentioned protective systems are confirmed to be in compliance with the requirement of paragraph 9 of directive 94/9/EC, including all published alterations and amendments according to EC-Certificate of Conformity No. IBExU 00 ATEX 2094 X issued on 06.12.2000 by IBExU – Institut für Sicherheitstechnik GmbH (Institute for Safety Technique), Freiberg – Notified Body, Reg.-No. 0637

Normative References: EN 12874, EN 1127-1

Corresponding documents:

operating instructions,
installation and maintenance
directions

Date 02.02.2001

DR-ES-DN-IIA.doc

Braunschweiger Flammenfilter GmbH

Manager Engineering (Leinemann)

Manager Quality Assurance (Schulze)

PROTEGO®, FLAMMENFILTER® und FLAMEFILTER®
are international registered trademarks of
Braunschweiger Flammenfilter GmbH.

**Braunschweiger
Flammenfilter**



DIN-EN-ISO 9001
DIN-ISO 14001

IBExU 98
ATEX Q001

ASME VIII.1
U-Stamp



für Sicherheit und Umweltschutz